

Technical Compliance Statement



中国认可
国际互认
检测
TESTING
CNAS L8469

Ref. No.: ACWE-RC220029 (ACWE-C1W2201053)

For the following equipment

Applicant : GoodWe Technologies Co., Ltd.
Manufacturer : GoodWe Technologies Co., Ltd.
Product : Grid-Tied PV Inverter
Model Number : (1)GW100K-HT(2)GW110K-HT(3)GW120K-HT
(4)GW73KLV-HT (5)GW75K-HT (6)GW80K-HT
Brand : GOODWE

We, **AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.** hereby certify that the above product has been tested by us with the listed standards. The test data & results are issued on the EMC test report No. **ACWE-E2009011C**.

Emission: EN IEC 61000-6-3:2021, EN 61000-6-3:2007+A1:2011+AC:2012,
EN IEC 61000-6-4:2019, EN 61000-6-4:2007+A1:2011
(IEC 61000-6-3:2020, IEC 61000-6-4:2018) and
AS/NZS 61000.6.3: 2012; AS/NZS 61000.6.4: 2020
EN 55011:2016+A11:2020; EN 55011:2016+A2:2021
EN IEC 61000-3-11:2019, EN 61000-3-11:2000
EN 61000-3-12:2011+AC:2013, EN 61000-3-12:2011
(IEC 61000-3-11:2017, IEC 61000-3-12:2011)

Immunity: EN IEC 61000-6-1:2019, EN 61000-6-1:2007,
EN IEC 61000-6-2:2019, EN 61000-6-2:2005+AC:2005
(IEC 61000-6-1:2016, IEC 61000-6-2:2016)
(IEC 61000-4-2:2008, IEC 61000-4-3:2020, IEC 61000-4-4:2012,
IEC 61000-4-5:2014+A1:2017, IEC 61000-4-6:2013+COR1:2015,
IEC 61000-4-8:2009, IEC 61000-4-34:2005+A1:2009)

Part of the standard is not included in Audix's scope, but the test capability can meet regulatory requirement.

Jan.18, 2022

Ken Lu/ Vice General Manager

AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.



Deutsche
Akkreditierungsstelle
D-PL-18968-01-00

The statement is based on a single evaluation of one sample of the above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test lab logo.